


**MAIN FLOOR PLAN - MECHANICAL**  
 SCALE: 1/8" = 1'-0"



**PLAN NOTES:**

- INSTALL UL RATED SMOKE DETECTOR IN RETURN AIR DUCTWORK OF ROOFTOP UNIT FOR EMERGENCY FAN SHUT-DOWN.
- RUN EXHAUST DUCT IN CEILING / TRUSS SPACE AS HIGH AS POSSIBLE AND RISE EXHAUST DUCT UP THRU ROOF TO ROOF CAP ABOVE. MAINTAIN 10'-0" CLEARANCE FROM ROOFTOP UNIT OUTSIDE AIR INTAKE.

**Myers ■ Anderson**  
 ■ Architecture  
 ■ Interior Design  
 ■ Landscape Architecture  
 101 North Main Street • Pocatello, Idaho 83204 • Tel. (208) 232-3711 • Fax. (208) 232-5762  
 849 Front Street, Suite 202 • Evanston, Wyoming 82930 • Tel. (307) 789-0934

**BEAR LAKE COUNTY COURTHOUSE**  
**PARIS, IDAHO --- BEAR LAKE COUNTY**


**MAIN FLOOR MECHANICAL PLAN**

CONTRACTOR SHALL VERIFY ALL DIMENSIONS & CONDITIONS SHOWN OR IMPLIED.

DRAWING SCALE APPLIES TO 22" X 34" SHEET SIZE

REVISION DATE

ORIGINAL DRAWING SIGNED BY: DMAYNE C. SUDWEEKS  
 DATE ORIGINAL SIGNED: JAN. 9TH, 2019  
 ORIGINAL ON FILE AT ENGINEERED SYSTEMS ASSOCIATES  
 1355 EAST CENTER, POCATELLO, IDAHO 83201



**Engineered Systems Associates**  
 1355 EAST CENTER  
 POCATELLO, IDAHO 83201  
 PHONE: (208) 233-0501  
 FAX: (208) 233-0529  
 EMAIL: esa@engsystems.com  
 ESA JOB NUMBER: 18026

DRAWN BY: SR  
 CHECKED BY: DCS  
 JOB NUMBER: 46548-13B  
 PROJECT DATE: JAN, 2019  
 SHEET OF

**M101**