

PLAN NOTES:

- 1 2ND STAGE LP GAS REGULATOR SIZED FOR 1,143,000 BTU.
- 2 RISE 2" LP GAS LINE UP IN STUD SPACE OF WALL TO ATTIC SPACE.
- 3 RISE LP GAS LINE UP THRU ROOF AND CONNECT TO ROOFTOP UNIT. INSTALL SHUT-OFF VALVE, DIRT LEG AND FLEXIBLE CONNECTION ON GAS LINE ON ROOF. SEAL ROOF PENETRATION WEATHERTIGHT.
- 4 SEE CIVIL SITE PLAN FOR CONTINUATION OF 3/4" HIGH PRESSURE LP GAS LINE UNDERGROUND TO NEW UNDERGROUND LP TANK FARM.
- 5 DROP 3/4" PUMPED CONDENSATE DRAIN LINE DOWN IN WALL BEHIND LAVATORY AND CONNECT TO SINK SIDE OF P-TRAP USING A DISHWASHER CONNECTION. SEE DETAIL ON SHEET P102.
- 6 2ND STAGE LP GAS REGULATOR SIZED FOR 2260,000 BTU SERVING ONLY EMERGENCY LP GAS GENERATOR.
- 7 CONNECT 1-1/4" LP GAS LINE FROM 2ND STAGE REGULATOR TO EMERGENCY LP GAS GENERATOR (SEE ELEC. DWGS.) COMPLETE WITH SHUT-OFF VALVE, FLEXIBLE CONNECTION AND DIRT LEG.
- 8 SEE CIVIL SITE PLAN C-102 FOR CONTINUATION OF 1" HIGH PRESSURE LP GAS LINE UNDERGROUND TO NEW UNDERGROUND LP TANK FARM.
- 9 PROVIDE FULL COVERAGE FIRE SPRINKLER SYSTEM AS REQUIRED BY NFPA-13.

NOTE:
SEE LARGE SCALE
TOILET ROOM PLAN
ON SHEET P102 FOR
PIPING IN THIS
AREA.

MAIN FLOOR PLAN - PLUMBING
SCALE: 1/8" = 1'-0"



Myers ■ Anderson
 ■ Architecture
 ■ Interior Design
 ■ Landscape Architecture
 101 North Main Street • Pocatello, Idaho 83204 • Tel. (208) 232-3711 • Fax. (208) 232-3762
 849 Front Street, Suite 202 • Evanston, Wyoming 82930 • Tel. (307) 789-0954

BEAR LAKE COUNTY COURTHOUSE
PARIS, IDAHO --- BEAR LAKE COUNTY


SHEET TITLE:
**MAIN FLOOR
 PLUMBING
 PLAN**

CONTRACTOR SHALL VERIFY
 ALL DIMENSIONS & CONDITIONS
 SHOWN OR IMPLIED

DRAWING SCALE APPLIES TO
 22" X 34" SHEET SIZE

REVISION	DATE

ORIGINAL DRAWING SIGNED BY: DWAYNE C. SUDWEEKS
 DATE ORIGINAL SIGNED: JAN. 9TH, 2019
 ORIGINAL ON FILE AT ENGINEERED SYSTEMS ASSOCIATES
 1355 EAST CENTER, POCATELLO, IDAHO 83201



**Engineered
 Systems
 Associates**
 1355 EAST CENTER
 POCATELLO, IDAHO 83201
 PHONE: (208) 233-0501
 FAX: (208) 233-0529
 EMAIL: esa@engsystems.com
 ESA JOB NUMBER: 18026

DRAWN BY: SR
 CHECKED BY: DCS
 JOB NUMBER: 46548-13B
 PROJECT DATE: JAN, 2019
 SHEET OF

P101