



POCATELLO, IDAHO 83201 FAX: (208) 233-0529 EMAIL: esa@engsystems.com ESA JOB NUMBER: 19025

Engineered **Systems**

PLAN NOTES:

1) SEE SITE PLAN FOR CONTINUATION.


2) INSTALL 6" WASTE LINE IN BOTTOM OF DRAINAGE PIT COMPLETE WITH 6" P-TRAP AND 2" VENT LINE RUNNING OVER TO ADJACENT WALL AS SHOWN. SEE ARCH' PLANS FOR DRAINAGE PIT DETAILS AND SEALING OF CONCRETE.

CLUBHOUSE EDGE MATI WAS

PLUMBING LEGEND DESCRIPTION VENT VTR VENT THRU ROOF CO CLEANOUT WALL CLEANOUT COTG CLEANOUT TO GRADE PIPE DROP PIPE RISE BALL TYPE ISOLATION VALVE ---- SOIL OR WASTE PIPING ----- VENT LINE PIPING DOMESTIC COLD WATER PIPING FIRE SPRINKLER LINE · GAS PIPING CONDENSATE DRAIN PIPING

GENERAL NOTES:

- A- THE CONTRACTOR SHALL CHECK AND VERIFY ALL DIMENSIONS AND CONNECTIONS ON THE JOB SITE. ALL WORK SHALL BE EXECUTED FROM MEASUREMENTS TAKEN AT THE SITE.
- B- THE MECHANICAL CONTRACTOR SHALL BE RESPONSIBLE TO INSURE PROPER CODE CLEARANCES FOR ELECTRICAL AND MECHANICAL ACCESS WHEN INSTALLING ANY EQUIPMENT SUPPLIED BY THE MECHANICAL CONTRACTOR.
- C- IT IS CRITICAL THAT THIS CONTRACTOR COORDINATE EQUIPMENT LOCATIONS WITH PIPING, DUCTWORK, ELECTRICAL CONDUIT AND BUILDING STRUCTURE TO INSURE CODE COMPLIANCE.
- D- CEILING DIFFUSERS ARE SHOWN IN APPROXIMATE LOCATIONS. REFER TO LIGHTING PLANS AND REFLECTED CEILING PLAN FOR EXACT LOCATIONS.
- DUCT DIMENSIONS CALLED OUT ON DRAWINGS ARE INSIDE FREE AREA DIMENSIONS. ACOUSTICAL DUCT LINER ARE TO BE ADDED TO OVERALL MEASUREMENTS.
- ALL DUCTWORK AND PIPING WHICH PASSES THRU FIRE RATED WALLS TO BE FIRE STOPPED WITH APPROVED FOAM OR SEALANT. REFER TO SPECIFICATIONS FOR APPROVED MANUFACTURES.



aughlin