


MAIN LEVEL MECHANICAL/ELECTRICAL FLOOR PLAN
 SCALE: 1/8" = 1'-0"



PLAN NOTES:

- ① UNIT HEATER TO BE RELOCATED FROM RIGBY. PROVIDE NEW FLUE, SUPPORT RODS, THERMOSTAT AND GAS CONNECTIONS. INSTALL AS PER MANUFACTURE INSTRUCTIONS. SEE DETAILS ON SHEET M200. MOUNT UNIT AS HIGH AS POSSIBLE TO MAINTAIN OH DOOR CLEARANCE HEIGHT.
- ② RUN NEW 5 PSI GAS LINE FROM LOCATION TO NEW EQUIPMENT AS SHOWN. RUN AS HIGH AS POSSIBLE. SEE DETAILS ON SHEET MP200.
- ③ CONNECT TO 1-1/4" GAS LINE TO EXISTING GAS AT THIS LOCATION.
- ④ INSTALL NEW 4" DOUBLE FLUE & INTAKE AIR WITH CONCENTRIC FLUE. SEE DETAILS ON SHEET ME201. SEAL ROOF PENETRATIONS WEATHER TIGHT.
- ⑤ PROVIDE NEW DISCONNECT SWITCH AND CONNECT (2) #12 1/2" C WITH GROUND TO NEAREST EXISTING PANEL AS REQUIRED. PROVIDE NEW 20 AMP SINGLE POLE BREAKER AS NECESSARY.
- ⑥ INSTALL NEW 7 DAY PROGRAMMABLE THERMOSTAT FOR RELOCATED UNIT HEATER.

Myers Anderson

- Architecture
- Interior Design
- Historic Preservation

122 South Main Street • Pocatello, Idaho 83204 • Tel: (208) 232-3741 • Fax: (208) 232-3782
 927 Main Street, Suite 300 • Evanston, Wyoming 82930 • Tel: (307) 789-0934

PROJECT:
 ITD RIGBY & IDAHO FALLS
 SHOP HVAC REPLACEMENT/
 UPGRADE
RIGBY/IDAHO FALLS, IDAHO

SHEET TITLE:
 IDAHO FALLS
 MAIN FLOOR
 PLAN

CONTRACTOR SHALL VERIFY ALL DIMENSIONS & CONDITIONS SHOWN OR IMPLIED.

DRAWING SCALE APPLIES TO 22" X 34" SHEET SIZE

REVISION DATE


DRAWN BY:

CHECKED BY:

JOB NUMBER: 96548-13B

PROJECT DATE: OCT 2019

SHEET **ME102**



Engineered Systems Associates
 1355 EAST CENTER
 POCATELLO, IDAHO 83201
 PHONE: (208) 233-0501
 FAX: (208) 233-0529
 EMAIL: eso@engsystems.com
 ESA JOB NUMBER: 19066