


MECHANICAL DEMO FLOOR PLAN

SCALE: 1/8" = 1'-0"



PLAN NOTES:

- 1 NO WORK TO BE DONE IN THIS ROOM. PROTECT DURING CONSTRUCTION.
- 2 REMOVE AND DISPOSE OF EXISTING CONDENSING UNIT, SUPPORTS, REFRIGERATION LINES AND COVERS. REMOVE & CAP ALL ACCESSIBLE REFRIGERATION LINES. CAPTURE AND DISPOSE OF R-22 REFRIGERANT PROPERLY.
- 3 EXISTING CONTROLS TO BE REPLACED WITH NEW. SEE SHEET ME-2 FOR NEW. RE-USE EXISTING CONDUIT OR J-BOX AS MUCH AS POSSIBLE.
- 4 EXISTING IRRIGATION TO REMAIN. PROTECT DURING CONSTRUCTION.
- 5 EXISTING EQUIPMENT TO REMAIN. PROTECT DURING CONSTRUCTION.
- 6 EXISTING THERMOSTATS TO REMAIN. PROTECT DURING CONSTRUCTION.
- 7 EXISTING FURNACE TO REMAIN. PROTECT DURING CONSTRUCTION.

ELEC. PLAN NOTES:

- A EXISTING DISCONNECT AND ASSOCIATED J-BOXES TO BE REMOVED AND DISPOSED OF. REMOVE CONNECTION BACK TO MAIN BREAKER. SEE SHEET ME-2 FOR NEW PANEL "C".
- B EXISTING DISCONNECT TO REMAIN. PROTECT DURING CONSTRUCTION.

MECHANICAL LEGEND

SYMBOL	DESCRIPTION
	ELECTRONIC THERMOSTAT
	EQUIPMENT SYMBOL
	HAND DAMPER
	ROUND BRANCH DUCT WITH HAND DAMPER
	INSULATED FLEXIBLE DUCT
	RETURN AIR OR EXHAUST GRILLE
	CEILING DIFFUSER
	ROOF MOUNTED UPBLAST EXHAUST FAN

FIRE NOTES:

- A THE CONTRACTOR SHALL FIRE CAULK ALL DUCT OR PIPE PENETRATIONS THRU FIRE RATED WALLS, FLOORS, OR CEILINGS.
- B THE CONTRACTOR SHALL INSTALL INTUMESCENT FIRE BLOCKS ON PLASTIC PENETRATIONS THRU FIRE RATED WALLS, FLOORS, OR CEILINGS.



Engineered Systems Associates
Mechanical Engineers
 Dwayne Sudweeks P.E., Dave Hansen P.E., Tanner Davis P.E.
 1355 East Center - Pocatello, Idaho 83201
 Phone: (208) 233-0501 email: esa@engsystems.com

PROPERTY # 503-9002
HYAC REPLACEMENT FOR:
LDS SHOSHONE 1st WARD
 SHOSHONE, IDAHO
MECHANICAL DEMO FLOOR PLAN

PROJECT:
 PROFESSIONAL ENGINEER
 LICENSED
 STATE OF IDAHO
 TANNER C. DAVIS
 Jun 27, 2022

DRWN. BY:	CKD. BY:
TCD	DCS
JOB NO.	DATE:
22096	06/27/22

SHEET:
ME-1
 OF: 6