# ADDENDUM NUMBER ONE

February 28, 2019

To all bidders of record for the work titled:

# Madison School District #321 Middle School HVAC Remodel

Project Number: 746

Please notify everyone concerned, including suppliers as to the issuance and contents of this Addendum prior to the date of bid opening. This Addendum is a part of the contract documents and modifies them as follows:

This Addendum consists of 4 pages(s) including attached drawing(s).

# I. GENERAL

N/A

#### II. SPECIFICATIONS

- A. Add Section 23 6320 Cooling Coils
- B. Prior approvals:
  - 1. 23 0514 Variable Frequency Drives

Yaskawa

2. 23 2123 - Circulating Pumps and Accessories

Twin City Hose, Taco, Mason Industries, Griswold Controls

3. 23 3114 - Low Pressure Steel Ductwork

Pottorff

4. 23 3115 - Variable Air Volume Boxes

Krueger, Daikin Applied, Anemostat

5. 23 6320 - Cooling Coils

RAE Coils, Daikin Applied, Precision Coils

# III. DRAWINGS

- A. Replace Sheet A1.3 Main Level Reflected Ceiling Plan, with attached
- B. Replace Sheet E1.1 Main Plan Lighting Demolition, with Attached

End of Addendum #1

#### **SECTION 23 6320 - COOLING COILS**

#### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

A. Drawings, General Provisions of Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, and Section 23 0501 apply to this Section.

# 1.2 TESTING


A. All standard coils shall be leak tested at 250 psig air under water.

#### PART 2 - PRODUCTS

#### 2.1 MANUFACTURED UNIT

- A. Fins shall be continuous aluminum configurated plate-fin type with full fin collars for accurate spacing and maximum fin-tube contact.
- B. Tubes shall be copper expanded into the fin collars for a permanent fin-tube bond and expanded into the header for a leak-tight joint at 250 psig air pressure under water.
- C. Headers shall be gray cast iron hydrostatically tested to 400 psi before assembly.
- D. Casings shall be constructed of 16 gauge, continuous coated galvanized steel with fins recessed into the channels to minimize air bypass. Top and bottom channels shall have 3/8" holes on 3" centers for mounting purposes.
- E. Approved Manufacturers:
  - 1. Trane
  - 2. Dunham-Bush
  - 3. Bohn

#### **END OF SECTION 23 6320**



BRENT A. MCFARLAND AR-2561

**(7)**  $\stackrel{\checkmark}{=}$ 

