

DIVISION 22: PLUMBING

22 0500 COMMON WORK RESULTS FOR PLUMBING

- 22 0501 COMMON PLUMBING REQUIREMENTS
- 22 0529 HANGERS AND SUPPORTS FOR PLUMBING PIPING AND EQUIPMENT
- 22 0553 IDENTIFICATION FOR PLUMBING PIPES AND EQUIPMENT
- 22 0719 PLUMBING PIPING INSULATION
- 22 0800 DEMOLITION AND REPAIR

22 1000 PLUMBING PIPES AND PUMPS

- 22 1116 DOMESTIC WATER PIPING
- 22 1313 FACILITY SEWERS
- 22 1319 FACILITY SANITARY SEWER SPECIALTIES

22 4000 PLUMBING FIXTURES

- 22 4213 COMMERCIAL WATER CLOSETS
- 22 4216 COMMERCIAL LAVATORIES

END OF TABLE OF CONTENTS

SECTION 22 0501**COMMON PLUMBING REQUIREMENTS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Common requirements and procedures for plumbing systems.
 - 2. Responsibility for proper operation of electrically powered equipment furnished under this Division.
 - 3. Furnish and install sealants relating to installation of systems installed under this Division.
 - 4. Furnish and install Firestop Penetration Systems for plumbing systems penetrations as described in Contract Documents.

- B. Products Furnished But Not Installed Under This Section:
 - 1. Sleeves, inserts, supports, and equipment for plumbing systems installed under other Sections.

- C. Related Requirements:
 - 1. Section 07 8400: 'Firestopping' for quality of penetration firestop systems to be used on Project and submittal requirements.
 - 2. Section 07 9213: 'Elastomeric Joint Sealant' for quality at building exterior.
 - 3. Sections Under 09 9000 Heading: 'Paints And Coatings' for painting of plumbing items requiring field painting.
 - 4. Division 26: 'Electrical' for raceway and conduit, unless specified otherwise, and line voltage wiring.
 - 5. Slots and openings through floors, walls, ceilings, and roofs provided under other Divisions in their respective materials.

1.2 SUBMITTALS

- A. Action Submittals:
 - 1. Product Data:
 - a. Manufacturer's catalog data for each manufactured item.
 - 1) Provide section in submittal for each type of item of equipment. Include Manufacturer's catalog data of each manufactured item and enough information to show compliance with Contract Document requirements. Literature shall show capacities and size of equipment used and be marked indicating each specific item with applicable data underlined.
 - 2) Include name, address, and phone number of each supplier.

- B. Informational Submittals:
 - 1. Qualification Statement:
 - a. Plumbing Subcontractor:
 - 1) Provide Qualification documentation if requested by Architect or Owner.
 - b. Installer:
 - 1) Provide Qualification documentation if requested by Architect or Owner.

- C. Closeout Submittals:
 - 1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Operations and Maintenance Data (Modify and add to requirements of Section 01 7800):
 - 1) At beginning of PLUMBING section of Operations And Maintenance Manual, provide master index showing items included:
 - a) Provide name, address, and phone number of Architect, Architect's Mechanical Engineer, General Contractor, and Plumbing subcontractor.

- b) Identify maintenance instructions by using same equipment identification used in Contract Drawings. Maintenance instructions shall include:
 - (1) List of plumbing equipment used indicating name, model, serial number, and nameplate data of each item together with number and name associated with each system item.
 - (2) Manufacturer's maintenance instructions for each piece of plumbing equipment installed in Project. Instructions shall include name of vendor, installation instructions, parts numbers and lists, operation instructions of equipment, and maintenance instructions.
- c) Provide operating instructions to include:
 - (1) General description of fire protection system.
 - (2) Step by step procedure to follow for shutting down system or putting system into operation.
- b. Warranty Documentation:
 - 1) Include copies of warranties required in individual Sections of Division 22.

1.3 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 - 1. Perform work in accordance with applicable provisions of Plumbing Codes applicable to Project. Provide materials and labor necessary to comply with rules, regulations, and ordinances.
 - 2. In case of differences between building codes, laws, local ordinances, utility company regulations, and Contract Documents, the most stringent shall govern. Notify Architect in writing of such differences before performing work affected by such differences.
 - 3. Identification:
 - a. Motor and equipment name plates as well as applicable UL / ULC and AGA / CGA labels shall be in place when Project is turned over to Owner.
- B. Qualifications. Requirements of Section 01 4301 applies, but not limited to following:
 - 1. Plumbing Subcontractor:
 - a. Company specializing in performing work of this section.
 - 1) Minimum five (5) years experience in plumbing installations.
 - 2) Minimum five (5) satisfactorily completed installations in past three (3) years of projects similar in size, scope, and complexity required for this project before bidding.
 - b. Upon request, submit documentation.
 - 2. Installer:
 - a. Licensed for area of Project.
 - b. Designate one (1) individual as project foremen who shall be on site at all times during installation and experienced with installation procedures required for this project.
 - c. Upon request, submit documentation.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Delivery And Acceptance Requirements:
 - 1. Accept valves on site in shipping containers with labeling in place.
 - 2. Provide temporary protective coating on cast iron and steel valves.
 - 3. Provide temporary end caps and closures on piping and fittings. Maintain in place until installation.
- B. Storage And Handling Requirements:
 - 1. In addition to requirements specified in Division 01, stored material shall be readily accessible for inspection by Architect until installed.
 - 2. Store items subject to moisture damage in dry, heated spaces.

1.5 WARRANTY

- A. Manufacturer Warranty:
 - 1. Provide certificates of warranty for each piece of equipment made out in favor of Owner.
- B. Special Warranty:
 - 1. Guarantee plumbing systems to be free from noise in operation that may develop from failure to construct system in accordance with Contract Documents.
 - 2. If plumbing sub-contractor with offices located more than 150 miles (240 km) from Project site is used, provide service / warranty work agreement for warranty period with local plumbing sub-contractor approved by Architect. Include copy of service / warranty agreement in warranty section of Operation And Maintenance Manual.

PART 2 - PRODUCTS

2.1 COMPONENTS

- A. Components shall bear Manufacturer's name and trade name. Equipment and materials of same general type shall be of same make throughout work to provide uniform appearance, operation, and maintenance.
- B. Pipe And Pipe Fittings:
 - 1. Weld-O-Let and Screw-O-Let fittings are acceptable.
 - 2. Use domestic made pipe and pipe fittings on Project, except non-domestic made cast iron pipe and fittings by MATCO-NORCA are acceptable.
- C. Sleeves:
 - 1. General:
 - a. Two sizes larger than bare pipe or insulation on insulated pipe.
 - 2. In Concrete And Masonry:
 - a. Sleeves through outside walls, interior shear walls, and footings shall be schedule 80 black steel pipe with welded plate.
 - 3. In Framing And Suspended Floor Slabs:
 - a. Standard weight galvanized iron pipe, Schedule 40 PVC, or 14 ga (2 mm) galvanized sheet metal.
- D. Valves:
 - 1. Valves of same type shall be of same manufacturer.

PART 3 - EXECUTION

3.1 INSTALLERS

- A. Acceptable Installers:
 - 1. Meet Quality Assurance Installer Qualifications as specified in Part 1 of this specification.

3.2 EXAMINATION

- A. Drawings:
 - 1. Plumbing Drawings show general arrangement of piping, equipment, etc. Follow as closely as actual building construction and work of other trades will permit.
 - 2. Consider Architectural and Structural Drawings part of this work insofar as these drawings furnish information relating to design and construction of building. These drawings take precedence over Plumbing Drawings.

3. Because of small scale of Drawings, it is not possible to indicate all offsets, fittings, and accessories that may be required. Investigate structural and finish conditions affecting this work and arrange work accordingly, providing such fittings, valves, and accessories required to meet conditions.
- B. Verification Of Conditions:
1. Examine premises to understand conditions that may affect performance of work of this Division before submitting proposals for this work. Examine adjoining work on which plumbing work is dependent for efficiency and report work that requires correction.
 2. Ensure that items to be furnished fit space available. Make necessary field measurements to ascertain space requirements including those for connections and furnish and install equipment of size and shape so final installation shall suit true intent and meaning of Contract Documents. If approval is received by Addendum or Change Order to use other than originally specified items, be responsible for specified capacities and for ensuring that items to be furnished will fit space available.
 3. Check that slots and openings provided under other Divisions through floors, walls, ceilings, and roofs are properly located. Perform cutting and patching caused by neglecting to coordinate with Divisions providing slots and openings at no additional cost to Owner.
 4. No subsequent allowance for time or money will be considered for any consequence related to failure to examine site conditions.

3.3 PREPARATION

- A. Changes Due To Equipment Selection:
1. Where equipment specified or otherwise approved requires different arrangement or connections from that shown in Contract Documents, submit drawings showing proposed installations.
 2. If proposed changes are approved, install equipment to operate properly and in harmony with intent of Contract Documents. Make incidental changes in piping, ductwork, supports, installation, wiring, heaters, panelboards, and as otherwise necessary.
 3. Provide additional motors, valves, controllers, fittings, and other equipment required for proper operation of systems resulting from selection of equipment.
 4. Be responsible for proper location of rough-in and connections provided under other Divisions.

3.4 INSTALLATION

- A. Interface With Other Work:
1. Furnish exact location of electrical connections and complete information on motor controls to installer of electrical system.
 2. Furnish sleeves, inserts, supports, and equipment that are to be installed by others in sufficient time to be incorporated into construction as work proceeds. Locate these items and confirm that they are properly installed.
- B. Cut carefully to minimize necessity for repairs to previously installed or existing work. Do not cut beams, columns, or trusses.
- C. Locating Equipment:
1. Arrange pipes and equipment to permit ready access to valves, cocks, unions, traps, and to clear openings of doors and access panels.
 2. Adjust locations of pipes, equipment, and fixtures to accommodate work to interferences anticipated and encountered.
 3. Install plumbing work to permit removal of equipment and parts of equipment requiring periodic replacement or maintenance without damage to or interference with other parts of equipment or structure.
 4. Determine exact route and location of each pipe before fabrication.
 - a. Right-Of-Way:
 - 1) Lines that pitch shall have right-of-way over those that do not pitch. For example, plumbing drains shall normally have right-of-way.

- 2) Lines whose elevations cannot be changed shall have right-of-way over lines whose elevations can be changed.
- b. Offsets, Transitions, and Changes in Direction:
 - 1) Make offsets, transitions, and changes in direction in pipes as required to maintain proper head room and pitch of sloping lines whether or not indicated on Drawings.
 - 2) Furnish and install all traps, air vents, sanitary vents, and devices as required to effect these offsets, transitions, and changes in direction.
- D. Penetration Firestops:
 1. Install Penetration Firestop System appropriate for penetration at plumbing systems penetrations through walls, ceilings, roofs, and top plates of walls.
- E. Sealants:
 1. Seal openings through building exterior caused by penetrations of elements of plumbing systems.
 2. Furnish and install acoustical sealant to seal penetrations through acoustically insulated walls and ceilings.
- F. Furnish and install complete system of piping, valved as indicated or as necessary to completely control entire apparatus:
 1. Pipe drawings are diagrammatic and indicate general location and connections. Piping may have to be offset, lowered, or raised as required or directed at site. This does not relieve this Division from responsibility for proper installation of plumbing systems.
 2. Arrange piping to not interfere with removal of other equipment, ducts, or devices, or block access to doors, windows, or access openings:
 - a. Arrange so as to facilitate removal of tube bundles.
 - b. Provide accessible flanges or ground joint unions, as applicable for type of piping specified, at connections to equipment and on bypasses.
 - 1) Make connections of dissimilar metals with di-electric unions.
 - 2) Install valves and unions ahead of traps and strainers. Provide unions on both sides of traps.
 - c. Do not use reducing bushings, bull head tees, close nipples, or running couplings. Street elbows are allowed only on potable water pipe **3/4 inch (19 mm)** in diameter and smaller.
 - d. Install piping systems so they may be easily drained
 - e. Install piping to insure noiseless circulation.
 - f. Place valves and specialties to permit easy operation and access. Valves shall be regulated, packed, and glands adjusted at completion of work before final acceptance.
 3. Do not install piping in shear walls.
 4. Cut piping accurately to measurements established at site. Remove burr and cutting slag from pipes.
 5. Work piping into place without springing or forcing. Make piping connections to pumps and other equipment without strain at piping connection. Remove bolts in flanged connections or disconnect piping to demonstrate that piping has been so connected, if requested.
 6. Make changes in direction with proper fittings.
 7. Expansion of Thermoplastic Pipe:
 - a. Provide for expansion in every **30 feet (9 meters)** of straight run.
 - b. Provide **12 inch (300 mm)** offset below roof line in each vent line penetrating roof.
 8. Expansion of PEX Pipe: Allow for expansion and contraction of PEX pipe as recommended by Pipe Manufacturer.
- G. Sleeves:
 1. Do not place sleeves around soil, waste, vent, or roof drain lines passing through concrete slabs on grade.
 2. Provide sleeves around pipes passing through concrete or masonry floors, walls, partitions, or structural members. Seal sleeves with specified sealants. Follow Pipe Manufacturer's recommendations for PEX pipe penetrations through studs and floor slabs.
 3. Sleeves through floors shall extend **1/4 inch (6 mm)** above floor finish in mechanical equipment rooms above basement floor. In other rooms, sleeves shall be flush with floor.
 4. Sleeves through floors and foundation walls shall be watertight.
- H. Escutcheons:

1. Provide spring clamp plates where pipes run through walls, floors, or ceilings and are exposed in finished locations of building. Plates shall be chrome plated heavy brass of plain pattern and shall be set tight on pipe and to building surface.

3.5 REPAIR / RESTORATION

- A. Each Section of this Division shall bear expense of cutting, patching, repairing, and replacing of work of other Sections required because of its fault, error, tardiness, or because of damage done by it:
 1. Patch and repair walls, floors, ceilings, and roofs with materials of same quality and appearance as adjacent surfaces unless otherwise shown.
 2. Surface finishes shall exactly match existing finishes of same materials.

3.6 FIELD QUALITY CONTROL

- A. Field Tests:
 1. Perform tests on plumbing piping systems. Furnish devices required for testing purposes.
- B. Non-Conforming Work:
 1. Replace material or workmanship proven defective with sound material at no additional cost to Owner.
 2. Repeat tests on new material, if requested.

3.7 CLEANING

- A. Remove dirt, grease, and other foreign matter from each length of piping before installation:
 1. After each section of piping used for movement of water or steam is installed, flush with clean water, except where specified otherwise.
 2. Arrange temporary flushing connections for each section of piping and arrange for flushing total piping system.
 3. Provide temporary cross connections and water supply for flushing and drainage and remove after completion of work.
- B. Clean exposed piping, equipment, and fixtures. Remove stickers from fixtures.

3.8 CLOSEOUT ACTIVITIES

- A. Instruction of Owner:
 1. Instruct building maintenance personnel and Stake Physical Facilities Representative in operation and maintenance of plumbing systems utilizing Operation And Maintenance Manual when so doing.
 2. Conduct instruction period after Substantial Completion inspection when systems are properly working and before final payment is made.

3.9 PROTECTION

- A. Protect piping systems from entry of foreign materials by temporary covers, completing sections of the work, and isolating parts of completed system. Cap or plug open ends of pipes and equipment to keep dirt and other foreign materials out of system. Do not use plugs of rags, wool, cotton waste, or similar materials.

END OF SECTION

SECTION 22 0529**HANGERS AND SUPPORTS FOR PLUMBING PIPING AND EQUIPMENT****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Common hanger and support requirements and procedures for plumbing systems.
- B. Products Installed But Not Furnished Under This Section:
 - 1. Paint identification for gas piping used in HVAC equipment.
- C. Related Requirements:
 - 1. Section 07 8400: 'Firestopping' for quality of Penetration Firestop Systems to be used on Project and submittal requirements.
 - 2. Sections Under 09 9000 Heading: Painting of mechanical items requiring field painting.
 - 3. Slots and openings through floors, walls, ceilings, and roofs provided under other Divisions in their respective materials.
 - 4. Section 23 0529: 'Hangers And Supports For HVAC Piping And Equipment' for gas piping used with HVAC equipment.
 - 5. Section 23 0553: 'Identification For HVAC Piping And Equipment' for paint identification of gas piping used with HVAC equipment.

1.2 SUBMITTALS

- A. Action Submittals:
 - 1. Product Data:
 - a. Manufacturer's catalog data for each manufactured item.

PART 2 - PRODUCTS**2.1 ASSEMBLIES**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Anvil International, Portsmouth, NH www.anvilintl.com.
 - b. Cooper B-Line, Highland, IL www.b-line.com.
 - c. Unistrut, Wayne, MI www.tyco-unistrut.com.
- B. Materials:
 - 1. Hangers, Rods, And Inserts
 - a. Galvanized and UL approved for service intended.
 - b. Support horizontal piping from hangers or on roller assemblies with channel supports, except where trapeze type hangers are explicitly shown on Drawings. Hangers shall have double nuts.
 - 1) Support insulated pipes **2 inches (50 mm)** in diameter and smaller with adjustable swivel ring hanger with insulation protection shield. Gauge and length of shield shall be in accordance with Anvil design data.
 - a) Type Two Acceptable Products:
 - (1) Swivel Ring Hanger: Anvil Fig. 69.

- (2) Insulation Protection Shield: Anvil Fig. 167.
- (3) Equals by Cooper B-Line.
- 2) Support insulated pipes **2-1/2 inches (64 mm)** in diameter and larger with clevis hanger or roller assembly with an insulation protection shield. Gauge and length of shield shall be according to Anvil design data.
 - a) Type Two Acceptable Products:
 - (1) Clevis Hanger: Anvil Fig. 260.
 - (2) Roller Assembly: Anvil Fig. 171.
 - (3) Insulation Protection Shield: Anvil Fig. 167.
 - (4) Equals by Cooper B-Line.
- 3) Support uninsulated copper pipe **2 inches (50 mm)** in diameter and smaller from swivel ring hanger, copper plated and otherwise fully suitable for use with copper tubing. Support non-copper uninsulated pipes from swivel ring hanger.
 - a) Type Two Acceptable Products:
 - (1) Swivel Ring Hanger For Copper Pipe: Anvil Fig. CT-69.
 - (2) Swivel Ring Hanger For Other Pipe: Anvil Fig. 69.
 - (3) Equals by Cooper B-Line.
- 4) Support uninsulated copper pipe **2-1/2 inches (64 mm)** in diameter and larger from clevis hanger, copper plated hangers and otherwise fully suitable for use with copper tubing. Support non-copper uninsulated pipes from clevis hanger.
 - a) Type Two Acceptable Products:
 - (1) Clevis Hanger For Copper Pipe: Anvil Fig. CT-65.
 - (2) Clevis Hanger For Other Pipe: Anvil Fig. 260.
 - (3) Equals by Cooper B-Line.
- c. Support rods for single pipe shall be in accordance with following table:

Rod Diameter	Pipe Size	Rod Diameter	Pipe Size
3/8 inch	2 inches and smaller	10 mm	50 mm and smaller
1/2 inch	2-1/2 to 3-1/2 inches	13 mm	64 mm to 88 mm
5/8 inch	4 to 5 inches	16 mm	100 mm to 125 mm
3/4 inch	6 inches	19 mm	150 mm
7/8 inch	8 to 12 inches	22 mm	200 mm to 300 mm

- d. Support rods for multiple pipe supported on steel angle trapeze hangers shall be in accordance with following table:

Rods		Number of Pipes per Hanger for Each Pipe Size						
Number	Diameter	2 Inch	2.5 Inch	3 Inch	4 Inch	5 Inch	6 Inch	8 Inch
2	3/8 Inch	Two	0	0	0	0	0	0
2	1/2 Inch	Three	Three	Two	0	0	0	0
2	5/8 Inch	Six	Four	Three	Two	0	0	0
2	5/8 Inch	Nine	Seven	Five	Three	Two	Two	0
2	5/8 Inch	Twelve	Nine	Seven	Five	Three	Two	Two

Rods		Number of Pipes per Hanger for Each Pipe Size						
Number	Diameter	50mm	64mm	75mm	100mm	125mm	150mm	200mm
2	10 mm	Two	0	0	0	0	0	0
2	13 mm	Three	Three	Two	0	0	0	0
2	16 mm	Six	Four	Three	Two	0	0	0
2	19 mm	Nine	Seven	Five	Three	Two	Two	0
2	22 mm	Twelve	Nine	Seven	Five	Three	Two	Two

- 1) Size trapeze angles so bending stress is less than **10,000 psi (69 MPa)**.
- e. Riser Clamps For Vertical Piping:
 - 1) Type Two Acceptable Products:
 - a) Anvil Fig. 261.

- b) Equals by Cooper B-Line.
- f. Concrete Inserts:
 - 1) Individual Inserts:
 - a) Suitable for special nuts size **3/8 inch (9.5 mm)** through **7/8 inch (22 mm)** with yoke to receive concrete reinforcing rods, and with malleable iron lugs for attaching to forms.
 - b) Type Two Acceptable Products:
 - (1) Anvil Fig. 282.
 - (2) Equals by Cooper B-Line.
 - 2) Continuous Inserts:
 - a) Class Two Quality Standard: Equal to Unistrut P-3200 series.
- g. Steel Deck Bracket:
 - 1) Class Two Quality Standard: Equal to Unistrut P1000 with clamp nut, minimum **6 inch (150 mm)** length.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Piping:
 - 1. Properly support piping and make adequate provisions for expansion, contraction, slope, and anchorage.
 - a. Except for underground pipe, suspend piping from roof trusses or clamp to vertical walls using Unistrut and clamps. Do not hang pipe from other pipe, equipment, or ductwork. Laying of piping on any building element is not allowed.
 - b. Supports For Horizontal Piping:
 - 1) Support metal piping at **96 inches (2 400 mm)** on center maximum for pipe **1-1/4 inches (32 mm)** or larger and **72 inches (1 800 mm)** on center maximum for pipe **1-1/8 inch (29 mm)** or less.
 - 2) Support thermoplastic pipe at **48 inches (1 200 mm)** on center maximum.
 - 3) Support PEX pipe at **32 inches (800 mm)** minimum on center.
 - 4) Provide support at each elbow. Install additional support as required.
 - c. Supports for Vertical Piping:
 - 1) Place riser clamps at each floor or ceiling level.
 - 2) Securely support clamps by structural members, which in turn are supported directly from building structure.
 - 3) Provide clamps as necessary to brace pipe to wall.
 - d. Insulate hangers for copper pipe from piping by means of at least two layers of Scotch 33 plastic tape.
 - 2. Gas piping Identification:
 - a. Apply paint identification for gas piping used with HVAC equipment as specified in Section 23 0553.

END OF SECTION

SECTION 22 0553**IDENTIFICATION FOR PLUMBING PIPES AND EQUIPMENT****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
1. Furnish and install identification of plumbing piping and equipment as described in Contract Documents.

PART 2 - PRODUCTS**2.1 SYSTEM**

- A. Materials:
1. Labels:
 - a. Equipment Identification:
 - 1) Black formica, with white reveal when engraved.
 - 2) Lettering to be **3/16 inch (5 mm)** high minimum.
 2. Paint:
 - a. One Coat Primer:
 - 1) 6-2 Quick Drying Latex Primer Sealer over fabric covers.
 - 2) 6-205 Metal Primer under dark color paint.
 - 3) 6-6 Metal Primer under light color paint.
 - b. Finish Coats: Two coats 53 Line Acrylic Enamel.
 - c. Performance Standard: Paints specified are from Pittsburgh Paint & Glass (PPG), Pittsburgh, PA www.pittsburghpaints.com or PPG Canada Inc, Mississauga, ON (800) 263-4350 or (905) 238-6441.
 - d. Type Two Acceptable Products. See Section 01 6200.
 - 1) Paint of equal quality from following Manufacturers may be submitted for Architect's approval before use. Maintain specified colors, shades, and contrasts.
 - a) Benjamin Moore, Montvale, NJ www.benjaminmoore.com or Toronto, ON (800) 304-0304 or (416) 766-1176.
 - b) ICI Dulux, Cleveland, OH or ICI Paints Canada Inc, Concord, ON www.dulux.com.
 - c) Sherwin Williams, Cleveland, OH www.sherwin-williams.com.

PART 3 - EXECUTION**3.1 APPLICATION**



- A. Labels:
1. Identify following items with specified labels fastened to equipment with screws (unless noted otherwise):
 - a. Water Heaters.
 2. Engrave following data from Equipment Schedules on Drawings onto labels:
 - a. Equipment mark.
 - b. Room(s) served.
 - c. Panel and breaker from which unit is powered.
- B. Painting:

1. Only painted legends, directional arrows, and color bands are acceptable.
2. Locate identifying legends, directional arrows, and color bands at following points on exposed piping of each piping system:
 - a. Adjacent to each item of equipment.
 - b. At point of entry and exit where piping goes through wall.
 - c. On each riser and junction.
 - d. Every **25 feet (7.6 m)** on long continuous lines.
 - e. Stenciled symbols shall be one inch high and black.

3.2 ATTACHMENTS

A. Schedules:

1. Pipe Identification Schedule:
 - a. Apply stenciled symbols as follows:

Pipe Use	Abbreviation	Direction of Flow
Domestic Cold Water	CW	
Domestic Hot Water	HW	

END OF SECTION

SECTION 22 0719

PLUMBING PIPING INSULATION

PART 1 - GENERAL

1.1 SUMMARY

- A. Includes But Not Limited To:
 - 1. Furnish and install insulation on hot and cold water lines, fittings, valves, and accessories as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 22 1116: 'Domestic Water Piping'.

PART 2 - PRODUCTS

2.1 COMPONENTS

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Armacell, Mebane, NC www.armacell.com.
 - b. Childers Products Co, Eastlake, OH www.fosterproducts.com.
 - c. IMCOA, Youngsville, NC www.nomacokflex.com.
 - d. Johns-Manville, Denver, CO www.jm.com.
 - e. Knauf, Shelbyville, IN www.knauffiberglass.com.
 - f. Manson, Brossard, PQ, Canada www.isolationmanson.com.
 - g. Nomaco Inc, Yopungville, NC www.nomacokflex.com.
 - h. Owens-Corning, Toledo, OH www.owenscorning.com.
 - i. Speedline Corp, Solon, OH www.speedlinepvc.com.
- B. Materials:
 - 1. Above Grade Metal Piping:
 - a. Insulation For Piping:
 - 1) Snap-on glass fiber or melamine foam pipe insulation, or heavy density pipe insulation with factory vapor jacket.
 - 2) Insulation Thickness:

Service Water Temperature	Pipe Sizes		
	Up to 1-1/4 In	1-1/2 to 2 In	Over 2 In
170 - 180 Deg F	One In	1-1/2 In	2 In
140 - 160 Deg F	1/2 In	One In	1-1/2 In
45 - 130 Deg F	1/2 In	1/2 In	One In

Service Water Temperature	Pipe Sizes		
	Up to 32 mm	38 to 50 mm	Over 50 mm
77 - 82 Deg C	25 mm	38 mm	50 mm
60 - 71 Deg C	13 mm	25 mm	38 mm
7 - 54 Deg C	13 mm	13 mm	25 mm

- 3) Performance Standards: Fiberglas ASJ by Owens-Corning.
- 4) Type One Acceptable Manufacturers:

- a) Childers Products.
 - b) Knauf.
 - c) Manson.
 - d) Owens-Corning.
 - e) Johns-Manville.
 - f) Equal as approved by Architect before bidding. See Section 01 6200.
 - b. Fitting, Valve, And Accessory Covers:
 - 1) PVC.
 - 2) Performance Standard: Zeston by Johns-Manville.
 - 3) Type One Acceptable Manufacturers:
 - a) Knauf.
 - b) Speedline.
 - c) Johns-Manville.
 - d) Equal as approved by Architect before bidding. See Section 01 6200.
- 2. Pex Piping, Above And Below Grade:
 - a. Insulation:
 - 1) **1/2 inch (13 mm)** thick.
 - 2) Category Four Acceptable Products. See Section 01 6200 for definition of Categories:
 - a) SS Tubolit by Armacell.
 - b) ImcoLock by Imcoa.
 - c) Nomalock or Therma-Cel by Nomaco.
 - b. Joint Sealant:
 - 1) Category Four Acceptable Products. See Section 01 6200 for definition of Categories:
 - a) Armacell 520.
 - b) Nomaco K-Flex R-373.

PART 3 - EXECUTION

3.1 APPLICATION

- A. Above Grade Piping:
 - 1. Apply insulation to clean, dry piping with joints tightly butted.
 - 2. Install insulation in manner to facilitate removal for repairs. Place sections or blocks so least possible damage to insulation will result from inspection or repairs of piping or equipment.
 - 3. Piping up to **1-1/4 inch (32 mm)** Diameter:
 - a. Adhere 'factory applied vapor barrier jacket lap' smoothly and securely at longitudinal laps with white vapor barrier adhesive.
 - b. Adhere **3 inch (76 mm)** wide self-sealing butt joint strips over end joints.
 - 4. Piping **1-1/2 inches (38 mm)** Diameter And Larger:
 - a. Use broken-joint construction in application of two-layer covering.
 - b. Fill cracks and depressions with insulating cement mixed to thick plastic paste.
 - 1) Apply by hand in several layers to make up total specified thickness.
 - 2) Final layer shall have smooth uniform finish before application of covering.
 - 5. Fittings, Valves, And Accessories:
 - a. Do not apply insulation over flanged joints or victaulic couplings until piping has been brought up to operating temperature and flange bolts have been fully tightened. Insulate valves so wheel, stem, and packing nut are exposed.
 - b. Insulate with same type and thickness of insulation as pipe, with ends of insulation tucked snugly into throat of fitting and edges adjacent to pipe insulation tufted and tucked in.
 - c. Piping Up To **1-1/4 Inch (32 mm)** Diameter:
 - 1) Cover insulation with one piece fitting cover secured by stapling or taping ends to adjacent pipe covering.
 - 2) Alternate Method:
 - a) Insulate fittings, valves, and accessories with one inch of insulating cement and vapor seal with two **1/8 inch (3 mm)** wet coats of vapor barrier mastic reinforced with glass fabric extending **2 inches (50 mm)** onto adjacent insulation.

- d. Piping 1-1/2 inches (38 mm) To 2 Inches (50 mm):
 - 1) Insulate with hydraulic setting insulating cement or equal, to thickness equal to adjoining pipe insulation.
 - 2) Apply final coat of fitting mastic over insulating cement.
 - e. Piping 2-1/2 inch (64 mm) And Larger:
 - 1) Insulate with segments of molded insulation securely wired in place and coated with skim coat of insulating cement.
 - 2) Apply fitting mastic, fitting tape and finish with final coat of fitting mastic.
 6. Pipe Hangers:
 - a. Do not allow pipes to come in contact with hangers.
 - b. Pipe Shield:
 - 1) Provide schedule 40 PVC by 6 inch (150 mm) long at each clevis and/or unistrut type hanger.
 - 2) Provide 16 ga (1.64 mm) by 6 inch (150 mm) long galvanized shields at each pipe hanger to protect pipe insulation from crushing by clevis hanger.
 - 3) Provide 22 ga (0.85 mm) by 6 inch (150 mm) long galvanized shield at each pipe hanger to protect insulation from crushing by Unistrut type hanger.
 - c. At Pipe Hangers:
 - 1) Provide rigid calcium silicate insulation (100 psi (690 kPA) compressive strength) at least 2 inches (50 mm) beyond shield.
 7. Protect insulation wherever leak from valve stem or other source might drip on insulated surface, with aluminum cover or shield rolled up at edges and sufficiently large in area and of shape that dripping will not splash on surrounding insulation.
- B. Below Grade Piping:
1. Slip underground pipe insulation onto pipe and seal butt joints.
 2. Where slip-on technique is not possible, slit insulation, apply to pipe, and seal seams and joints.

END OF SECTION

SECTION 22 0800
DEMOLITION AND REPAIR

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings, General Provisions of Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, and Section 23 0501 apply to this Section.

1.2 SUMMARY

- A. Under this section remove obsolete piping and mechanical equipment and relocate, reconnect or replace existing piping affected by demolition or new construction. Remove concealed piping abandoned due to demolition or new construction, or cap piping flush with existing surfaces.

1.3 DRAWINGS AND EXISTING CONDITIONS

- A. All relocations, reconnections and removals are not necessarily indicated on the drawings. As such, the Contractor shall make adequate allowance in his proposal for this work as no extra charges will be allowed for these items.

PART 2 - PRODUCTS – Not Used

PART 3 - EXECUTION

3.1 TEMPORARY CONNECTIONS

- A. Where existing piping must remain in service to supply occupied areas during construction, provide temporary piping, connections, and equipment to maintain service to such areas. All shall be performed in a neat and safe manner to prevent injury to the building or its occupants.

3.2 DRILLING, CUTTING, PATCHING

- A. All Required drilling, cutting, block-outs and demolition work required for the removal and/or installation of the mechanical system is the responsibility of this Contractor.
- B. No joists, beams, girders, trusses or columns shall be cut by any Contractor without written permission from the Architect.
- C. The patching, repair, and finishing to existing or new surfaces is the responsibility of this Contractor, unless specifically called for under sections of specifications covering these materials.
- D. Disconnect all equipment that is to be removed or relocated. Relocate any existing equipment that obstructs new construction.

3.3 EXISTING PIPING TO REMAIN IN USE

- A. Where affected by demolition or new construction, relocate, replace, extend, or repair piping and equipment to allow continued use of same. Use methods and materials as specified for new construction.

3.4 MATERIALS AND EQUIPMENT REMOVED

- A. All obsolete materials, piping, and equipment shall become the property of the Contractor and be removed from the site promptly.

END OF SECTION

SECTION 22 1116
DOMESTIC WATER PIPING

PART 1 - GENERAL**1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Perform excavating and backfilling required by work of this Section.
 - 2. Furnish and install potable water piping complete with necessary valves, connections, and accessories inside building as described in Contract Documents.

- B. Related Requirements:
 - 1. Section 22 0501: 'Common Piping Requirements'.
 - 2. Section 22 0719: 'Plumbing Piping Insulation'.

1.2 REFERENCES

- A. Reference Standards:
 - 1. American National Standards Institute / American Society of Sanitary Engineers:
 - a. ANSI/ASSE 1003-2009, 'Water Pressure Reducing Valves for Domestic Water Distribution Systems'.
 - b. ANSI/ASSE 1017-2009, 'Performance Requirements for Temperature Actuated Mixing Valves for Hot Water Distribution Systems'.
 - c. ANSI/ASSE 1070-2015, 'Performance Requirements for Water Temperature Limiting Devices'.
 - 2. American Water Works Association:
 - a. AWWA C904-16, 'Cross-Linked Polyethylene (PEX) Pressure Pipe, 1/2 inch (12 mm) Through 3 inch (76 mm) for Water Service'.
 - 3. ASTM International:
 - a. ASTM B88-14, 'Standard Specification for Seamless Copper Water Tube'.
 - b. ASTM E84-15b, 'Standard Test Method for Surface Burning Characteristics of Building Materials'.
 - c. ASTM F876-15a, 'Standard Specification for Crosslinked Polyethylene (PEX) Tubing'.
 - d. ASTM F877-11a, 'Standard Specification for Crosslinked Polyethylene (PEX) Hot- and Cold-Water Distribution Systems'.
 - e. ASTM F1807-15, 'Standard Specification for Metal Insert Fittings Utilizing a Copper Crimp Ring for SDR9 Cross-linked Polyethylene (PEX) Tubing and SDR9 Polyethylene of Raised Temperature (PE-RT) Tubing'.
 - f. ASTM F2023-15, "Standard Test Method for Evaluating the Oxidative Resistance of Crosslinked Polyethylene (PEX) Tubing and Systems to Hot Chlorinated Water'.

1.3 SUBMITTALS

- A. Action Submittals:
 - 1. Product Data:
 - a. Manufacturer's Literature:
 - 1) PEX pipe and PEX pipe fittings.
 - 2. Samples:
 - a. PEX pipe fitting.

- B. Informational Submittals:
 - 1. Test And Evaluation Reports:

- a. Written report of sterilization test.

1.4 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 1. Meet NSF International Standards for materials or products that come into contact with drinking water, drinking water treatment chemicals, or both for chemical contaminants and impurities that are indirectly imparted to drinking water from products, components, and materials used in drinking water systems.

PART 2 - PRODUCTS

2.1 SYSTEMS

- A. Manufacturers:
 1. Manufacturer Contact List:
 - a. Aquatherm, Inc., Lindon, UT www.aquathermpipe.com.
 - b. Cash Acme, Cullman, AL www.cashacme.com
 - c. Cla-Val Company, Costa Mesa, CA or Cla-Val Canada Ltd, Beamsville, ON www.cla-val.com.
 - d. Conbraco Industries Inc, Matthews, NC www.conbraco.com or Conbraco (Honeywell Ltd), Scarborough, ON (416) 293-8111.
 - e. Hammond Valve, New Berlin, WI www.hammondvalve.com.
 - f. Handy & Harmon Products Div, Fairfield, CT www.handyharmon.com or Handy and Harmon of Canada Ltd, Rexdale, ON (800) 463-1465 or (416) 675-1860.
 - g. Harris Products Group, Cincinnati, OH www.harrisproductsgroup.com.
 - h. Honeywell Inc, Minneapolis, MN www.honeywell.com.
 - i. Leonard Valve Co, Cranston, RI www.leonardvalve.com.
 - j. Milwaukee Valve Co, New Berlin, WI www.milwaukeevalve.com.
 - k. Nibco Inc, Elkhart, IN www.nibco.com.
 - l. Rehau, Leesburg, VA www.rehau-na.com.
 - m. Sloan Valve Co, Franklin Park, IL www.sloanvalve.com.
 - n. Spence Engineering Co, Walden, NY www.spenceengineering.com.
 - o. Symmons Industries, Braintree, MA www.symmons.com.
 - p. Uponor Inc, Apple Valley, MN www.uponor-usa.com.
 - q. Viega ProPress, Wichita, KS www.viega-na.com.
 - r. Watts Regulator Co, Andover, MA www.wattsreg.com.
 - s. Wilkins (Zurn Wilkins), Paso Robles, CA www.zurn.com.
 - t. Zurn PEX, Inc., Commerce, TX www.zurnpex.com.
- B. Materials:
 1. Design Criteria:
 - a. All drinking water products, components, and materials above and below grade used in drinking water systems must meet NSF International Standards for Lead Free.
 - b. No CPVC allowed.
 2. Pipe:
 - a. Copper:
 - 1) Above-Grade:
 - a) Meet requirements of ASTM B88, Type L.
 - 2) Below-Grade:
 - a) Meet requirements of ASTM B88, Type K. **3/4 inch (19 mm)** minimum under slabs.
 - b) **2 inches (50 mm)** And Smaller: Annealed soft drawn.
 - c) **2-1/2 inches (64 mm)** And Larger: Hard Drawn.
 - b. Cross-Linked Polyethylene (PEX):
 - 1) Certified with NSF International against NSF Standards NSF/ANSI 14, NSF/ANSI 61, NSF/ANSI 372, and NSF P171 Protocol.

- 2) Copper tube size (CTS) outside dimensions and Standard Dimension Ratio (SDR) of 9.
 - 3) Pressure rated for **160 psi (1.10 MPa)** at **73 deg F (22.8 deg C)**, **100 psi (0.69 MPa)** at **180 deg F (82 deg C)**, and **80 psi (0.552 MPa)** at **200 deg F (93 deg C)**.
 - 4) Marked with Manufacturer's name, design pressure and temperature ratings, and third party certification stamp for NSF-PW.
 - 5) Manufactured by Engel or peroxide method (PEX-A) or by silane method (PEX-B).
 - 6) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Raupex by Rehau.
 - b) Wirsbo Aquapex by Uponor.
 - c) ViegaPEX by Viega.
 - d) Zurn PEX by Zurn PEX.
3. Fittings:
 - a. For Copper Pipe: Wrought copper.
 - b. For PEX Pipe:
 - 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Everloc by Rehau.
 - b) Viega PEX Press Zero Lead Fittings with attached stainless steel sleeves or Viega PEX Press Radel-R Polymer with attached stainless steel sleeves by Viega.
 - c) ProPEX fittings by Uponor including EP flow-through multiport tees.
 - d) Zurn PEX XL, DZR and CR fittings.
 4. Connections For Copper Pipe:
 - a. Above-Grade:
 - 1) Sweat copper type with 95/5 or 96/4 Tin-Antimony solder, Bridgit solder, or Silvabrite 100 solder. Use only lead-free solder.
 - 2) Viega ProPress System
 - b. Below Grade:
 - 1) Brazed using following type rods:
 - a) Copper to Copper Connections:
 - (1) AWS Classification BCuP-4 Copper Phosphorus (6 percent silver).
 - (2) AWS Classification BCuP-5 Copper Phosphorus (15 percent silver).
 - 2) Copper to Brass or Copper to Steel Connections: AWS Classification BAg-5 Silver (45 percent silver).
 - 3) Do not use rods containing Cadmium.
 - 4) Brazing Flux:
 - a) Approved Products:
 - (1) Stay-Silv white brazing flux by Harris Product Group.
 - (2) High quality silver solder flux by Handy & Harmon.
 - 5) Joints under slabs acceptable only if allowed by local codes.
 5. Ball Valves:
 - a. Use ball valves exclusively unless otherwise specified. Ball valves shall be by single manufacturer from approved list below.
 - b. Valves shall be two-piece, full port for **150 psi (1.03 MPa)** SWP.
 - 1) Operate with flow in either direction, suitable for throttling and tight shut-off.
 - 2) Body: Bronze, **150 psig (1.03 MPa)** wsp at **350 deg F (177 deg C)** and **400 psig (2.76 MPa)** wog.
 - 3) Seat: Bubble tight at **100 psig (0.69 MPa)** under water.
 - c. Class One Quality Standard: Nibco T585 or S585.
 - 1) Equal by Conbraco 'Apollo,' Hammond, Milwaukee, or Watts.
 6. Mixing Valve For Lavatories:
 - a. Solid brass construction and CSA B125 certified.
 - b. Includes integral check valves and inlet screen. Features advanced paraffin-based actuation technology.
 - c. Flow of **5.7 GPM (21.58 LPM)** with maximum **10 psi (69 kPa)** pressure drop. Perform to minimum flow of **0.5 GPM (1.89 LPM)** in accordance with ASSE 1070.
 - d. Set for **110 deg F (43 deg C)** Service.
 - e. Match Construction Drawings for connection sizes.
 - f. Class One Quality Standard: Powers LFLM495. See Section 01 6200.
 - g. Acceptable Manufacturers: Lawler, Leonard, Powers, Sloan, Symmons, and Watts.

PART 3 - EXECUTION**3.1 INSTALLATION**

- A. Locate cold water lines a minimum of **6 inches (150 mm)** from hot water line.

3.2 FIELD QUALITY CONTROL

- A. Field Tests:
 - 1. Before pipes are covered, test systems in presence of Architect/Engineer at **125 psig (0.86 MPa)** hydrostatic pressure for four (4) hours and show no leaks.
 - 2. Disconnect equipment not suitable for **125 psig (0.86 MPa)** pressure from piping system during test period.

3.3 CLEANING

- A. Sterilize potable water system with solution containing 200 parts per million minimum of available chlorine and maintaining pH of 7.5 minimum. Introduce chlorinating materials into system in manner approved by Architect/Engineer. Allow sterilization solution to remain for twenty-four (24) hours and open and close valves and faucets several times during that time.
- B. After sterilization, flush solution from system with clean water until residual chlorine content is less than 0.2 parts per million.
- C. Water system will not be accepted until negative bacteriological test is made on water taken from system. Repeat dosing as necessary until such negative test is accomplished.

END OF SECTION

SECTION 22 1313**FACILITY SANITARY SEWERS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install soil, waste, and vent piping systems within building.
- B. Related Requirements:
 - 1. Sections Under 07 3000 Heading: Furnishing and installing of roof jacks and pipe flashing at roof.
 - 2. Section 07 8400: 'Firestopping' for quality of firestopping material.
 - 3. Section 22 0501: 'Common Plumbing Requirements'.
 - 4. Section 22 1319: 'Facility Sanitary Sewer Specialties' for furnishing of sewer specialties.

1.2 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Conference: Participate in pre-installation conference specified in Section 03 3111.

1.3 REFERENCES

- A. Reference Standards:
 - 1. ASTM International:
 - a. ASTM D2235-04(2011), 'Standard Specification for Solvent Cement for Acrylonitrile-Butadiene-Styrene (ABS) Plastic Pipe and Fittings'.
 - b. ASTM D2321-14, 'Standard Practice for Underground Installation of Thermoplastic Pipe for Sewers and Other Gravity-Flow Applications'.
 - c. ASTM D2564-12, 'Standard Specification for Solvent Cements for Poly (Vinyl Chloride) (PVC) Plastic Piping Systems'.
 - d. ASTM D3034-14, 'Standard Specification for Type PSM Poly (Vinyl Chloride) (PVC) Sewer Pipe and Fittings'.
 - e. ASTM F628-12, 'Standard Specification for Acrylonitrile-Butadiene-Styrene (ABS) Schedule 40 Plastic Drain, Waste, and Vent Pipe With a Cellular Core'.
 - f. ASTM F656-15, 'Standard Specification for Primers for Use in Solvent Cement Joints of Poly (Vinyl Chloride) (PVC) Plastic Pipe and Fittings'.
 - g. ASTM F891-10, 'Standard Specification for Coextruded Poly(Vinyl Chloride) (PVC) Plastic Pipe With a Cellular Core'.

PART 2 - PRODUCTS**2.1 SYSTEMS**

- A. Performance:
 - 1. Design Criteria:
 - a. Minimum size of waste piping installed under floor slab on grade shall be **2 inches (50 mm)**.
- B. Materials:

1. Piping And Fittings: PVC Schedule 40 cellular core plastic pipe and pipe fittings meeting requirements of ASTM F891, joined using cement primer meeting requirements of ASTM F656 and pipe cement meeting requirements of ASTM D2564.
 - a. Furnish wall cleanouts with chrome wall cover and screw.
2. Piping And Fittings: ABS Schedule 40 cellular core plastic pipe and pipe fittings meeting requirements of ASTM F628, joined with pipe cement meeting requirements of ASTM D2235.
 - a. Furnish wall cleanouts with chrome wall cover and screw.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Thermoplastic Pipe And Fittings:
 1. General: Piping and joints shall be clean and installed according to Manufacturer's recommendations. Break down contaminated joints, clean seats and gaskets and reinstall.
 2. Above Grade: Locate pipe hangers every **4 feet (1.2 m)** on center maximum and at elbows.
- B. Install piping so cleanouts may be installed as follows:
 1. At every 135 degrees of accumulative change in direction for horizontal lines.
 2. Every **100 feet (30 meters)** of horizontal run.
 3. Extend piping to accessible surface. Do not install piping so cleanouts must be installed in carpeted floors. In such locations, configure piping so wall type cleanouts may be used.
- C. Each fixture and appliance discharging water into sanitary sewer or building sewer lines shall have seal trap in connection with complete venting system so gasses pass freely to atmosphere with no pressure or siphon condition on water seal.
- D. Vent entire waste system to atmosphere. Join lines together in fewest practicable numbers before projecting above roof. Set back vent lines so they will not pierce roof near edge or valley. Vent line terminations shall be:
 1. **6 inches (150 mm)** minimum above roof and **12 inches (300 mm)** minimum from any vertical surface.
 2. Same size as vent pipe.
 3. In areas where minimum design temperature is below **0 deg F (minus 18 deg C)** or where frost or snow closure may be possible:
 - a. Vent line terminations shall be same size as vent pipe, except no smaller than **2 inches (50 mm)** in diameter.
 - b. Vents shall terminate **10 inches (250 mm)** minimum above roof or higher if required by local codes.
- E. Furnish and install firestopping at penetrations of fire-rated structures as required under Sections 07 8400 and 22 0501.
- F. If test Tees are used for testing, plug Tees so wall finish can be installed. Do not leave as exposed cleanouts.

3.2 FIELD QUALITY CONTROL

- A. Field Tests:
 1. Conduct tests for leaks and defective work. Notify Architect before testing.

END OF SECTION

SECTION 22 1319**FACILITY SANITARY SEWER SPECIALTIES****PART 1 - GENERAL****1.1 SUMMARY**

- A. Products Furnished But Not Installed Under this Section as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 22 0501: 'Common Plumbing Requirements'.
 - 2. Section 22 1119: 'Domestic Water Piping Specialties'.
 - 3. Section 22 1313: 'Facility Sanitary Sewers' for installation of miscellaneous sanitary sewer specialties.

PART 2 - PRODUCTS**2.1 SYSTEMS**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. Josam Co, Michigan City, IN www.josam.com.
 - b. Jay R. Smith Manufacturing Co, Montgomery, AL www.jrsmith.com.
 - c. Mifab Manufacturing Inc, Chicago, IL www.mifab.com.
 - d. Proset Systems, Lawrenceville, GA www.prosetsystems.com.
 - e. Sioux Chief Manufacturing Co, Peculiar, MO www.siouxchief.com.
 - f. Sureseal Manufacturing, Tacoma WA www.thesureseal.com.
 - 1) Contact Information:
 - a) All Areas except Idaho and Utah: Rick Ensley (253) 564-0624, rick@thesureseal.com.
 - b) Idaho and Utah Areas: Mark Evans, phone (801) 748-1222, mark@franklinjames.com.
 - g. Wade Div Tyler Pipe, Tyler, TX www.wadedrains.com.
 - h. Watts Drainage, Spindale, NC www.watts.com or Watts Industries, Burlington, ON, Canada www.wattscda.com.
 - i. Zurn Industries, LLC, Erie PA www.zurn.com. or Zurn Industries Ltd, Mississauga, ON (905) 795-8844.
- B. Performance:
 - 1. Design Criteria:
 - a. All materials NOT required to be low lead compliant.
- C. Components:
 - 1. Drains And Drain Accessories:
 - a. Floor Drain FD-1:
 - 1) Approved types with deep seal trap and chrome plated strainer.
 - 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Josam: 30000-50-Z-5A.
 - b) J. R. Smith: 2010-A.
 - c) Mifab: F-1100-C.
 - d) Sioux Chief: 832.
 - e) Wade: 1100.
 - f) Watts: FD-200-A.
 - g) Zurn: Z-415.

D. Accessories:

1. Drain Accessories:

E. Materials:

1. Trap Primers:

- a. Provide and install Precision Plumbing Products "prime-time" (or approved equal) trap priming assembly.
- b. Complete assembly including:
 - 1) Atmospheric vacuum breaker.
 - 2) Pre-set 24 hour clock.
 - 3) Manual over-ride switch.
 - 4) 120v/220v solenoid valve.
 - 5) 3/4" FNPT connection with isolation valve.
 - 6) Calibrated manifold for equal water distribution.
 - 7) 5/8" outlet compression fittings (for 1/2" Pex piping connections).
 - 8) Manifold outlets as specified on plans.
 - 9) 12"x12"x4" Nema 1 metal cabinet with cover plate for surface mounting.
- c. Operation:
 - 1) Priming assembly will supply a minimum of 20 oz. of potable water at 20 psig at a preset factory setting of 10 seconds.
 - 2) The entire unit is pre-assembled in a steel cabinet for surface mounting.
 - 3) The priming assembly must be mounted above the finished floor.

PART 3 - EXECUTION: Not Used

END OF SECTION

SECTION 22 4213**COMMERCIAL WATER CLOSETS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Includes But Not Limited To:
 - 1. Furnish and install plumbing fixtures as described in Contract Documents.
- B. Related Requirements:
 - 1. Section 07 9213: 'Elastomeric Joint Sealants' for sealants used between fixtures and other substrates.
 - 2. Section 22 0501: 'Common Plumbing Requirements'.
 - 3. Section 22 1116: 'Domestic Water Piping'.

1.2 REFERENCES

- A. Reference Standards:
 - 1. American Society of Mechanical Engineers / CSA Group (Canadian Standards Association):
 - a. ASME A112.19.2-2013/CSA B45.1-13, 'Ceramic Plumbing Fixtures'.

1.3 SUBMITTALS

- A. Closeout Submittals:
 - 1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Operation and Maintenance Data:
 - 1) Sensor Operated operation and maintenance manuals.

PART 2 - PRODUCTS**2.1 ASSEMBLIES**

- A. Manufacturers:
 - 1. Manufacturer Contact List:
 - a. American Standard Brands, Piscataway, NJ www.americanstandard-us.com or American Standard Canada, Mississauga, ON www.americanstandard.ca.
 - b. AMTC - Advanced Modern Technologies Corp, Woodland Hills, CA www.amtccorporation.com.
 - c. Bemis Manufacturing Co, Sheboygan Falls, WI www.bemismfg.com.
 - d. Beneke by Sanderson Plumbing Products, Columbus, MS www.sppi.com.
 - e. Church Seat Co, Sheboygan Falls WI www.churchseats.com.
 - f. Delta Faucet Co, Indianapolis, IN www.deltafaucet.com or Delta Faucet Canada, London, ON (519) 659-3626.
 - g. Dearborn Brass, Cleveland, OH www.dearbornbrass.com.
 - h. Gerber Plumbing Fixtures LLC, Woodridge, IL www.gerberonline.com.
 - i. Josam Co, Michigan City, IN www.josam.com.
 - j. Jay R. Smith Mfg. Co, Montgomery, AL www.jrsmith.com.
 - k. Kohler Co Plumbing Div, Kohler, WI www.us.kohler.com.
 - l. McGuire Manufacturing Co, Cheshire, CT www.mcguiremfg.com.
 - m. Mifab Manufacturing Inc, Amherst, NY www.mifab.com.

- n. Moen Incorporated, North Olmsted, OH, or Moen Canada, Oakville, ON www.moen.com.
- o. Olsonite Corp, Newnan, GA www.olsonite.net or Olsonite Co Ltd, Tilbury, ON (519) 682-1240.
- p. Sloan Valve Co, Franklin Park, IL www.sloanvalve.com.
- q. South Fork Manufacturing, Coalville, UT (801) 953-3001 www.dirt-grabber.com.
- r. Toto U.S.A., Inc., Morrow, GA www.totousa.com
- s. Wade Div Tyler Pipe, Tyler, TX www.wadedrains.com.
- t. Watts Drainage, Spindale, NC www.wattsdrainage.com or Watts Industries, Burlington, ON, Canada www.wattscda.com.
- u. Zurn Industries, LLC, Erie PA www.zurn.com. or Zurn Industries Ltd, Mississauga, ON (905) 795-8844.

B. Performance:

1. Design Criteria:

- a. Meet or exceed ASME A112.19.2/CSA B45.1 for Vitreous China Plumbing Fixtures.
- b. Interior exposed pipe, valves, and fixture trim, including trim behind custom casework doors, shall be chrome plated.
- c. All materials NOT required to be low lead compliant.
- d. Do not use toilets with effective flush volume of less than **1.28 gallons (4.8 liters)**.

C. Materials:

1. Water Closets:

a. Floor Mounted With Tank:

1) Standard Fixture:

- a) Water usage of **1.6 gallons (6 liters)** per flush.
- b) MaP Score of 1000 grams.
- c) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - (1) American Standard: Cadet 3 Elongated 215CA.004.
 - (2) Gerber: Avalanche AV-21-812.
 - (3) Kohler: Wellworth K-3978.
 - (4) Toto: 'Drake' CST744S.

2. Water Closet Accessories:

a. Seats:

- 1) Provide split front type with check hinge.
- 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Standard And Handicap Accessible Fixtures:
 - (1) American Standard: 5905.100SS.
 - (2) Bemis: 1655SSC.
 - (3) Beneke: 527 SS.
 - (4) Church: 9500SSC.
 - (5) Kohler: K-4731-C.
 - (6) Olsonite: 95SSC.
 - (7) Toto SC534.

b. Supply Pipe And Stop:

- 1) Provide chrome plated quarter-turn brass ball valve, **12 inch (300 mm)** braided stainless steel riser, and chrome-plated steel flange.
- 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) McGuire: BV2166CC.
 - b) Zurn: Z8804.

3. Urinals:

a. HEU (High-Efficiency Urinal) - Standard Fixture:

- 1) Water usage of **0.5 gallons (1.9 liters)** per flush.
- 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) American Standard: Washbrook FloWise 6590.001.
 - b) Gerber: Monitor 27-730.
 - c) Kohler: Bardon K-4904-ET.
 - d) Sloan SU-1009.
 - e) Toto: UT447E.

4. Urinal Accessories:

- a. Carrier / Support:
 - 1) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) Josam.
 - b) Jay R. Smith.
 - c) Mifab.
 - d) Wade.
 - e) Zurn.
- b. Flush Valve:
 - 1) HEU (High-Efficiency Urinal) - Standard:
 - a) Proximity sensor type with battery.
 - b) Low flow, 0.5 gallon (1.9 liters) per flush maximum.
 - c) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - (1) American Standard 6063.051.
 - (2) Delany: PL 1451-0.5.
 - (3) Delta: 81T231BTA factory set to 0.5 gallons per flush.
 - (4) Moen: 8315.
 - (5) Sloan: 8186-0.5.
 - (6) Zurn: ZER6003AV-EWS with maintenance override button.
- c. Flush Valve Filter:
 - 1) Required in following flush valves:
 - a) Sloan.
 - b) Zurn.
 - 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) SFDG1 'Dirt Grabber' by South Fork Manufacturing.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install each fixture with separate vent line. Do not circuit vent.
- B. Ensure provisions are made for proper support of fixtures and that rough-in piping is accurately set and protected from movement and damage.
 1. Seal wall-mounted fixtures around edges to wall with sealant specified in Section 07 9213 'Elastomeric Joint Sealants'.
 2. Attach wall-hung fixtures to carriers.
 3. Support fixture hanger or arm free of finished wall.
- C. Provide each individual fixture supply with accessible chrome-plated stop valve with hand wheel.
- D. Urinals: Install with accessible stop or control valve in each branch supply line.
- E. Water Closets:
 1. Floor or Wall Fixtures:
 - a. Make fixture connections with approved brand of cast iron flange, soldered or caulked securely to waste pipe. Make joints between fixtures and flanges tight with approved fixture setting compound or gaskets. Caulk between fixtures with sealant specified in Section 07 9213. Point edges.

3.2 CLEANING

- A. Polish chrome finish at completion of Project.

END OF SECTION

SECTION 22 4216
COMMERCIAL LAVATORIES

PART 1 - GENERAL

1.1 SUMMARY

- A. Includes But Not Limited To:
 - 1. Furnish and install plumbing fixtures as described in Contract Documents.

- B. Related Requirements:
 - 1. Section 07 9213: 'Elastomeric Joint Sealants' for sealants used between fixtures and other substrates.
 - 2. Section 22 0501: 'Common Plumbing Requirements'.
 - 3. Section 22 1116: 'Domestic Water Piping'.

1.2 REFERENCES

- A. Reference Standard:
 - 1. American National Standards Institute / International Code Council:
 - a. ANSI/ICC A117.1-2009, 'Standard for Accessible and Usable Buildings and Facilities'.
 - 2. American Society of Mechanical Engineers / Canadian Standards Association (CSA Group):
 - a. ASME A112.18.1-2012/CSA B125.1-12, 'Plumbing Supply Fittings'.
 - b. ASME A112.19.1-2013/CSA B45.2-13, 'Enamelled cast iron and enamelled steel plumbing fixtures'.
 - c. ASME A112.19.3-2008/CSA B45.4-08 (R2013), 'Stainless steel plumbing fixtures'.

1.3 QUALITY ASSURANCE

- A. Regulatory Agency Sustainability Approvals:
 - 1. Meet NSF International Standards for materials or products that come into contact with drinking water, drinking water treatment chemicals, or both for chemical contaminants and impurities that are indirectly imparted to drinking water from products, components, and materials used in drinking water systems.
 - 2. California only: California Assembly Bill 1953 (AB1953) Compliant for Lead Free.

1.4 SUBMITTALS

- A. Closeout Submittals:
 - 1. Include following in Operations And Maintenance Manual specified in Section 01 7800:
 - a. Warranty Documentation:
 - 1) Final, executed copy of Warranty.

1.5 WARRANTY

- A. Manufacturer Warranty:
 - 1. Manufacturer's standard Warranty against material or Manufacturing defects.

PART 2 - PRODUCTS**2.1 ASSEMBLIES****A. Manufacturers:****1. Manufacturer Contact List:**

- a. American Standard Brands, Piscataway, NJ www.americanstandard-us.com or American Standard Canada, Mississauga, ON www.americanstandard.ca.
- b. Brocar Products Inc, Cincinnati, OH www.brocar.com.
- c. CECO, Huntington Park, CA www.cecosinks.com.
- d. Chicago Faucet Co, Des Plaines, IL www.chicagofaucets.com.
- e. Dearborn Brass, Tyler, TX www.dearbornbrass.com.
- f. Delta Faucet Co, Indianapolis, IN www.deltafaucet.com or Delta Faucet Canada, London, ON (519) 659-3626.
- g. Engineered Brass Co. (EBC) (Just Manufacturing Co.), Franklin Park, IL www.justmfg.com.
- h. Elkay Manufacturing Co, Oak Brook, IL www.elkay.com.
- i. Gerber Plumbing Fixtures LLC, Woodridge, IL www.gerberonline.com.
- j. Josam Co, Michigan City, IN www.josam.com.
- k. Jay R. Smith Manufacturing Co, Montgomery, AL www.jrsmith.com.
- l. Just Manufacturing Co, Franklin Park, IL www.justsinks.com.
- m. Keeney Manufacturing Co, Newington, CT www.keeneymfg.com.
- n. Kindred USA, Midland, ON www.kindred-sinkware.com.
- o. Kohler Co Plumbing Div, Kohler, WI www.us.kohler.com.
- p. McGuire Manufacturing Co, Cheshire, CT www.mcquiremfg.com.
- q. Mifab Manufacturing Inc, Amherst, NY www.mifab.com.
- r. Moen Incorporated, North Olmsted, OH, or Moen Canada, Oakville, ON www.moen.com.
- s. Omni Flow Controls, Harbor City, CA www.chronomite.com or www.omniflowcontrols.com.
- t. Plumberex Specialty Products, Palm Springs, CA www.plumberex.com.
- u. Sloan Valve Co, Franklin Park, IL www.sloanvalve.com.
- v. Speakman Company, New Castle, DE www.speakmancompany.com.
- w. Symmons, Braintree, MA www.symmons.com.
- x. T & S Brass & Bronze Works Inc, Travelers Rest, SC www.tsbrass.com.
- y. TrueBro Inc, Collierville, TN www.truebro.com.
- z. Wade Div Tyler Pipe, Tyler, TX www.wadedrains.com.
- aa. Watts Drainage, Spindale, NC www.wattsdrainage.com or Watts Industries, Burlington, ON, Canada www.wattscda.com.
- bb. Zurn Commercial Brass, Sanford, NC www.zurn.com or Zurn Industries Ltd, Mississauga, ON (905) 795-8844.
- cc. Zurn Cast Metal, Erie, PA www.zurn.com.

B. Performance:**1. Design Criteria:**

- a. Interior exposed pipe, valves, and fixture trim, including trim behind custom casework doors, shall be chrome plated.
- b. Faucets and other fixture fittings shall conform to requirements of ASME A112.18.1/CSA B125.1.
- c. Lavatories shall conform to requirements of:
 - 1) Enamelled cast iron and enamelled steel fixtures.
 - a) ASME A112.19.1/CSA B45.2.
 - b) CSA B45.2/ASME A112.19.1.
 - 2) Stainless steel plumbing fixtures:
 - a) ASME A112.19.3/CSA B45.4.
 - b) CSA B45.4/ASME A112.19.3.

C. Components:**1. Lavatories And Fittings:**

- a. Standard Counter Top Lavatories:
 - 1) Size **20 by 17 inches** (**500 by 430 mm**) nominal.

- 2) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - a) American Standard: Aqualyn 0476.028.
 - b) Gerber: Luxoval 12-844.
 - c) Kohler: Pennington K-2196-4N.
- b. Lavatory Fittings:
 - 1) Faucet and Grid Strainer For Standard Sinks:
 - a) Design Criteria:
 - (1) Meet NSF International Standards for Lead Free.
 - b) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - (1) American Standard: Monterrey Two-Handle Centerset Lavatory Faucet with Vandal-Resistant Wrist Blade handles and grid strainer drain 5502.170.
 - (2) Chicago: 802CP with 327XCP.
 - (3) Delta: 2529HDF.
 - (4) Gerber: C4-44-412.
 - (5) Kohler: K-7404-5A with K-7715 strainer.
 - (6) Moen: 8215 with 14750 grid strainer.
 - (7) Speakman: SC 3072.
 - (8) T & S: B-0890 with B-0899 Grid Strainer.
 - (9) Zurn: Z81104 with McGuire 155A Grid Strainer.
 - 2) Flow Control Fitting:
 - a) Design Criteria:
 - (1) Meet NSF International Standards for Lead Free.
 - b) Accessories:
 - (1) Provide vandal-proof type in place of aerator. Flow shall be 0.5 gpm.
 - c) Category Four Approved Product. See Section 01 6200 for definitions of Categories:
 - (1) Omni L-200 Series by Chronomite Laboratories.
 - 3) Supply pipes with stops:
 - a) Design Criteria:
 - (1) Meet NSF International Standards for Lead Free.
 - b) Accessories:
 - (1) Provide chrome plated quarter-turn brass ball valve, 12 inches (305 mm) long braided stainless steel riser, and chrome-plated steel flange.
 - c) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - (1) McGuire: BV2165CC.
 - (2) Zurn: Z8804 LRQ-PC.
 - 4) Trap:
 - a) Description:
 - (1) 17 gauge (1.4 mm) tube 'P' trap, chrome plated.
 - b) Design Criteria:
 - (1) Not required to meet NSF International Standards for Lead Free.
 - c) Category Four Approved Products. See Section 01 6200 for definitions of Categories:
 - (1) Dearborn.
 - (2) Engineered Brass Company (EBC).
 - (3) Keeney Manufacturing.
 - (4) McGuire.
 - (5) Zurn.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install each fixture with separate vent line. Do not circuit vent.
- B. Ensure provisions are made for proper support of fixtures and that rough-in piping is accurately set and protected from movement and damage.

- C. Seal wall-mounted fixtures around edges to wall and counter top fixtures to countertop with sealant specified in Section 07 9213.
- D. Unless otherwise noted, provide each individual fixture supply with chrome-plated stop valve with hand wheel.
- E. Install fixtures with accessible stop or control valve in each hot and cold water branch supply line.

3.2 CLEANING

- A. Polish chrome finish at completion of Project.

END OF SECTION

END OF DIVISION 22