



March 26, 2021

ADDENDUM NO. TWO (2)

PROJECT: DPW 17-240
Idaho State University
CoT Nursing Remodel
Pocatello, Idaho

To: All Bidders

This addendum forms a part of the contract documents and modifies the original bidding documents as noted below. Except as affected by data included herein, all other parts of the contract documents shall remain in full force and effect. It shall be the sole responsibility of the bidder to appropriately disseminate this data to all concerned prior to the bid time and date. Acknowledge receipt of this addendum in the space provided on the bid form. Failure to do so may subject the bidder to disqualification.

This addendum consists of 1 page and 0 page attachment for a total of 1 page.

SPECIFICATION ITEMS:

Item S1 Specification Section 23 6220 Rooftop Heating-Cooling Unit: Add paragraph 2.1.K "Provide unit with web enabled programmable thermostat equal to Honeywell "Prestige"

PREBID APPROVAL ITEMS:

10 2226 & 10 2227	Operable Partitions: Hufcor
23 6220	Rooftop Heating-Cooling Unit: York
23 3114	Ductwork Dampers & Accessories: Pottorff, Hercules

END OF ADDENDUM NO. 2