

ADDENDUM

Project: LDS Teton 1, 2 Boiler Replacement

Project No.: 507515721010101

Addendum No.: 2

Project Address: 44 West Main St. Teton, ID

Date: August 6, 2021

Owner: Corporation of the Presiding Bishop of The Church of Jesus Christ
of Latter-day Saints, a Utah corporation sole

From (Architect): Engineered Systems Associates. 1355 E Center St. Pocatello, ID 83201

Instructions to Prospective Bidders:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and/or prior Addenda as noted below. All conditions, requirements, materials and workmanship are to be as described in the Contract Documents unless specifically stated otherwise. This Addendum consists of 1 page(s) and the attached drawing(s), Sheet(s) _____, dated _____

1. Changes to prior Addenda:

a. None

b.

2. Changes to Bidding Requirements:

a. Add Contractors to Bid Invitations - Jason Olson, Bingham Mechanical - jasonolson@binghammechanical.com - (208)-522-4484

b.

3. Changes to Conditions of the Contract:

a. Construction timeframe in the contract is 45 days. Due to longer than normal lead times, these 45 days won't start until the boilers arrive. If too late this fall, this timeframe could push the construction into the spring.

b.

4. Changes to Specifications:

a. None

b.

5. Changes to Drawings:

a. Sheet ME-1. Reference Note 5 - Two new 4" diameter Boiler flues to extend up through existing chimney to the top. Cap with MFG recommended weather cap.

b.

End of Addendum