

# ADDENDUM

---

Project: LDS Caldwell Boiler Replacement

Project No.: 503283021010101

Addendum No.: 1

Project Address: 519 South 12<sup>th</sup> Ave. Caldwell, ID 83605

Date: August 6, 2021

Owner: Corporation of the Presiding Bishop of The Church of Jesus Christ  
of Latter-day Saints, a Utah corporation sole

From (Architect): Engineered Systems Associates

---

## Instructions to Prospective Bidders:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and/or prior Addenda as noted below. All conditions, requirements, materials and workmanship are to be as described in the Contract Documents unless specifically stated otherwise. This Addendum consists of 1 page(s) and the attached drawing(s), Sheet(s) \_\_\_\_\_, dated \_\_\_\_\_

---

### 1. Changes to prior Addenda:

a. None

b.

### 2. Changes to Bidding Requirements:

a. None

b.

### 3. Changes to Conditions of the Contract:

a. Construction timeframe in the contract is 45 days. Due to longer than normal lead times, these 45 days won't start until the boilers arrive. If too late this fall, this timeframe could push the construction into the spring.

b.

### 4. Changes to Specifications:

a. Section 23 5227 - Boiler to include heat net control panel and power flame model C1-0 burner. (Or approved equal).

b.

### 5. Changes to Drawings:

a. Sheet ME-1 - Reference large scale boiler room. There is an existing emergency boiler shut down switch at the exit dorrway. A new switch will not be required. Interlock existing switch to shut down new boiler in case of emergency.

b.

**End of Addendum**