

ADDENDUM #003

Date: April 5, 2019

This Addendum applicable to work designated herein shall be understood to be and is an Addendum and as such shall be part of and included in the Contract.

To all bidders for furnishing all labor and materials necessary for:

Midway Elementary School Jefferson School District No. 251 Rigby, Idaho NBW Project #16071

Failure to acknowledge receipt of this Addendum on the bid proposal form may result in rejection of your bid.

STRUCTURAL

1. Sheet S1.0 - General Structural Notes call for Wall Sheathing Panel Edge Nailing to be 6" O.C. -This applies where panel edges occur on a stud. No additional blocking required at panel edges.

MECHANICAL

- 1. Sheet M3.2 Air Handler Unit Schedule -AH-1 to be trane CSAA025 or approved equal.
- 2. Sheet M3.2 Condensing Unit Schedule CU-1 to be trane RAUT-25 or approved equal.

MANUFACTURERS AND PRODUCT APPROVALS

The following manufacturers and products are acceptable subject to requirements of the specifications:

- 1. Specification Section 23 1185 Condensate Pumps: Skidmore
- 2. Specification Section 23 2166 Split System Heat Pump Units: Daikin
- 3. Specification Section 23 3114 Low Pressure Steel Ductwork: NCA Manufacturing, Air Rite Manufacturing, Pottorff, Hercules Industries
- 4. Specification Section 23 3400 Exhaust Fans: Soler & Palau, Twin City Fans
- 5. Specification Section 23 3713 Louvers: Pottorff
- 6. Specification Section 23 5417 High Eff Natural Gas Furnace: Ruud
- 7. Specification Section 23 5528 Unit Ventilators: Enviro-Tec, Magic Aire

- 8. Specification Section 23 5533 Unit Heaters: Rittling
- 9. Specification Section 23 5540 Electric Radiant Wall Heaters: Indeeco
- 10. Specification Section 23 5721 Cabinet Heaters: Enviro-Tec
- 11. Specification Section 23 6213 Air- Cooled Condensing Unit (2-5): Ruud
- 12. Specification Section 23 6215 Air Cooled Condensing Unit (6 and larger): Duham-Bush
- 13. Specification Section 23 6218 Air Handling Units with Coil: Duham-Bush

END OF ADDENDUM NO. 003